

<b>School Name: Doris Henderson Newcomers School</b>		<b>Report Date(s): 6/17/2021</b>	
<b>Date Test Conducted: 4/24/2021</b>		<b>Date Results Received: 4/30/2021</b>	
<b>Number of Faucets Tested: 5 (only kitchen samples collected, drinking fountains out-of-use)</b>			
<b>Lead Results</b>		<b>Copper Results</b>	
Results 15 ppb and above:	1	Results 1.3 ppm and above:	0
Results 10 ppb to below 15 ppb:	0	Detectable results below 1.3 ppm:	4
Detectable results below 10 ppb:	2	Results below detection level:	1
Results below detection level:	2		
<b>Number of Faucets Requiring Remedial Action: 1</b>			
<b>Location of Faucet</b>		<b>Action Taken</b>	<b>Date:</b>
Sample ID: DHN-001-024-KF-P		<input checked="" type="checkbox"/> Temporarily taken out of service:	5/4/2021
Location Description: DHN-001-024-KF-P: faucet located in kitchen		<input type="checkbox"/> Permanently taken out of service:	
		<input checked="" type="checkbox"/> Flush tested:	5/15/2021
		Flush test result: no exceedances	
		<input checked="" type="checkbox"/> Replaced:	5/24/2021
		<input checked="" type="checkbox"/> Retest:	6/5/2021
		Retest result: no exceedances	
		Other: _____	
		<input checked="" type="checkbox"/> Placed back in service on:	6/17/2021
<b>Daily School-Wide Flushing:</b>			
<input type="checkbox"/> Continue with protocol <input checked="" type="checkbox"/> Discontinue flushing protocol (date): 6/17/21 <input type="checkbox"/> Other (Describe: )			
This is a summary report prepared by Hart & Hickman, PC (H&H). H&H suggests that the full report be referred to with regard to findings, recommendations, and technical limitations for this sampling event.			