

School Name: Guilford Elementary		Report Date(s): 5/24/2021	
Date Test Conducted: 2/29/2020		Date Results Received: 3/9/2020	
Number of Faucets Tested: 17			
Lead Results		Copper Results	
Results 15 ppb and above:	1	Results 1.3 ppm and above:	0
Results 10 ppb to below 15 ppb:	0	Detectable results below 1.3 ppm:	16
Detectable results below 10 ppb:	0	Results below detection level:	1
Results below detection level:	16		
Number of Faucets Requiring Remedial Action: 1			
Location of Faucet		Action Taken	Date:
Sample ID: GIL-001-002-BP-P		<input checked="" type="checkbox"/> Temporarily taken out of service:	3/10/2020
Location Description: GIL-001-002-BP-P: braising pan in the kitchen		<input type="checkbox"/> Permanently taken out of service:	
		<input checked="" type="checkbox"/> Flush tested:	3/14/20*, 4/24/21*
		Flush test result: no exceedances	
		<input checked="" type="checkbox"/> Replaced:	2/24/21*, 5/12/21*
		<input checked="" type="checkbox"/> Retest:	4/10/21*, 5/15/21*
		Retest result: no exceedances	
		Other: _____	
		<input checked="" type="checkbox"/> Placed back in service on:	5/24/2021
* Faucet on braising pan was initially replaced 2/24/21. Subsequent 4/10/21 sampling indicated exceedances in the first-draw sample, but not the flush sample. The shut-off valve, fittings, and supply line were then replaced on 5/12/21. First-draw samples collected after the second replacement event indicated no exceedances.			
Daily School-Wide Flushing:			
<input type="checkbox"/> Continue with protocol			
<input checked="" type="checkbox"/> Discontinue flushing protocol (date): 5/24/21			
<input type="checkbox"/> Other (Describe:)			
This is a summary report prepared by Hart & Hickman, PC (H&H). H&H suggests that the full report be referred to with regard to findings, recommendations, and technical limitations for this sampling event.			