

Table 1
Summary of First-Draw Drinking Water Sample Analytical Results
Guilford County Schools
Hunter Elementary School
Greensboro, North Carolina
H&H Job No. GCS-001

Sample ID	Guilford County Sample Location Code	Sampling Date	Analytical Method	Lead	Copper
				ppb ⁽¹⁾	ppm ⁽²⁾
HUN-001-004-KF-P	004	4/10/2021	200.8	<2.0	0.0748
HUN-001-006-KF-P	006	4/10/2021		<2.0	0.0486
HUN-001-007-KF-P	007	4/10/2021		<2.0	0.0968
HUN-001-008-KF-P	008	4/10/2021		<2.0	0.0241
HUN-001-009-KF-P	009	4/10/2021		<2.0	<0.0020
HUN-001-020-KF-P	020	4/10/2021		<2.0	0.0631
District Action Threshold ⁽³⁾				10	1.3

Notes

- 1.) Lead results reported in parts per billion (ppb).
- 2.) Copper results reported in parts per million (ppm).
- 3.) Action threshold established by Guilford County Schools.