

Table 1
Summary of First-Draw Drinking Water Sample Analytical Results
Guilford County Schools
Simkins Elementary School
Greensboro, North Carolina
H&H Job No. GCS-001

Sample ID	Guilford County Sample Location Code	Sampling Date	Analytical Method	Lead	Copper
				ppb ⁽¹⁾	ppm ⁽²⁾
SIM-001-PK1-KF-P	PK1	6/18/2021	200.8	<1.0	0.836
SIM-001-PK2-KF-P	PK2	6/18/2021		<1.0	0.856
SIM-001-PK3-KF-P	PK3	6/18/2021		<1.0	0.740
SIM-001-PK4-KF-P	PK4	6/18/2021		<1.0	1.00
SIM-001-PK5-BP-P	PK5	6/18/2021		1.0	0.296
SIM-001-PK6-KF-P	PK6	6/18/2021		<1.0	0.735
SIM-001-PK7-IM-P	PK7	6/18/2021		<1.0	0.0060
District Action Threshold ⁽³⁾				10	1.3

Notes

- 1.) Lead results reported in parts per billion (ppb).
- 2.) Copper results reported in parts per million (ppm).
- 3.) Action threshold established by Guilford County Schools.