

Table 1
Summary of First-Draw Drinking Water Sample Analytical Results
Guilford County Schools
Southern Elementary School
Greensboro, North Carolina
H&H Job No. GCS-001

Sample ID	Guilford County Sample Location Code	Sampling Date	Analytical Method	Lead	Copper
				ppb ⁽¹⁾	ppm ⁽²⁾
SOU-001-PK1-KF-P	PK1	6/18/2021	200.8	7.5	0.769
SOU-001-PK2-BP-P	PK2	6/18/2021		1.8	0.407
SOU-001-PK3-KF-P	PK3	6/18/2021		2.1	0.669
SOU-001-PK4-KF-P	PK4	6/18/2021		1.5	0.420
SOU-001-PK5-IM-P	PK5	6/18/2021		<1.0	0.0058
District Action Threshold ⁽³⁾				10	1.3

Notes

- 1.) Lead results reported in parts per billion (ppb).
- 2.) Copper results reported in parts per million (ppm).
- 3.) Action threshold established by Guilford County Schools.