

School Name: Alamance Elementary School		Report Date (s): 5/14/2019; 8/19/2019	
Date Test Conducted: 5/1/2019		Date Results Received: 5/14/19	
Number of Faucets Tested: 25 (all GCS identified faucets used for drinking/food preparation)			
Lead Results		Copper Results	
Results 15 ppb and above: 0		Results 1.3 ppm and above: 0	
Results 10 ppb to below 15 ppb: 0		Detectable results below 1.3 ppm: 25	
Detectable results below 10 ppb: 0		Results below detection level: 0	
Results below detection level: 25			
Number of Faucets Requiring Remedial Action: 0			
Daily School-Wide Flushing: <input type="checkbox"/> Continue with protocol <input type="checkbox"/> Discontinue flushing protocol: mm/dd/yyyy <input checked="" type="checkbox"/> Other (Describe: Perform Periodic Flushing)			
This is a summary report prepared by ECS. ECS suggests that the full report be referred to with regards to findings, recommendations, and technical limitations for this sampling event.			