

School Name: Bessemer Elementary		Report Date (s): 6/17/2019; 8/19/2019	
Date Test Conducted: 5/1/19		Date Results Received: 5/13/19; 6/3/19	
Number of Faucets Tested: 35 (all GCS identified faucets used for drinking/food preparation)			
Lead Results		Copper Results	
Results 15 ppb and above: 1		Results 1.3 ppm and above: 0	
Results 10 ppb to below 15 ppb: 0		Detectable results below 1.3 ppm: 35	
Detectable results below 10 ppb: 2		Results below detection level: 0	
Results below detection level: 32			
Number of Faucets Requiring Remedial Action: 1			
Location of Faucet		Action Taken	
Sample ID: BES-009 Location description: Room 3 Drinking Station		X Temporarily Taken Out of Service: 5/14/19 X Permanently Taken Out of Service: 6/5/19 X Flush Tested: 5/15/19 Flush Test Result 6/3/19: ND (Lead) ___ Replaced: mm/dd/yyyy ___ Retest: mm/dd/yyyy Retest Result: ##### ___ Other: _____mm/dd/yyyy ___ Placed Back in Service on: mm/dd/yyyy	
Daily School-Wide Flushing: ___ Continue with protocol ___ Discontinue flushing protocol: mm/dd/yyyy <u>X</u> Other (Describe: <u>Perform Periodic Flushing</u>)			
This is a summary report prepared by ECS. ECS suggests that the full report be referred to with regards to findings, recommendations, and technical limitations for this sampling event.			