

<b>School Name: Gibsonville Elementary</b>		<b>Report Date(s): 11/13/2019</b>	
<b>Date Test Conducted: 11/2/2019</b>		<b>Date Results Received: 11/13/2019</b>	
<b>Number of Faucets Tested: 49</b>			
<b>Lead Results</b>		<b>Copper Results</b>	
Results 15 ppb and above:	0	Results 1.3 ppm and above:	0
Results 10 ppb to below 15 ppb:	0	Detectable results below 1.3 ppm:	48
Detectable results below 10 ppb:	1	Results below detection level:	1
Results below detection level:	48		
<b>Number of Faucets Requiring Remedial Action: 0</b>			
<b>Location of Faucet</b>		<b>Action Taken</b>	<b>Date:</b>
Sample ID:		<input type="checkbox"/> Temporarily taken out of service: <input type="checkbox"/> Permanently taken out of service: <input type="checkbox"/> Flush tested: Flush test result: <input type="checkbox"/> Replaced: <input type="checkbox"/> Retest: Retest result: Other: _____ <input type="checkbox"/> Placed back in service on:	
Location Description:			
<b>Daily School-Wide Flushing:</b>			
<input type="checkbox"/> Continue with protocol <input checked="" type="checkbox"/> Discontinue flushing protocol (date): <input type="checkbox"/> Other (Describe: _____)			
This is a summary report prepared by Hart & Hickman, PC (H&H). H&H suggests that the full report be referred to with regard to findings, recommendations, and technical limitations for this sampling event.			