

School Name: McLeansville Elementary		Report Date(s): 12/10/2019	
Date Test Conducted: 11/23/2019		Date Results Received: 12/6/2019	
Number of Faucets Tested: 21			
Lead Results		Copper Results	
Results 15 ppb and above:	0	Results 1.3 ppm and above:	0
Results 10 ppb to below 15 ppb:	0	Detectable results below 1.3 ppm:	20
Detectable results below 10 ppb:	0	Results below detection level:	1
Results below detection level:	21		
Number of Faucets Requiring Remedial Action: 0			
Location of Faucet		Action Taken	Date:
Sample ID:		<input type="checkbox"/> Temporarily taken out of service: <input type="checkbox"/> Permanently taken out of service: <input type="checkbox"/> Flush tested: Flush test result: <input type="checkbox"/> Replaced: <input type="checkbox"/> Retest: Retest result: Other: _____ <input type="checkbox"/> Placed back in service on:	
Location Description:			
Daily School-Wide Flushing:			
<input type="checkbox"/> Continue with protocol <input checked="" type="checkbox"/> Discontinue flushing protocol (date): <input type="checkbox"/> Other (Describe: _____)			
This is a summary report prepared by Hart & Hickman, PC (H&H). H&H suggests that the full report be referred to with regard to findings, recommendations, and technical limitations for this sampling event.			