

<b>School Name: Murphey Traditional Academy</b>		<b>Report Date(s): 1/7/2020</b>	
<b>Date Test Conducted: 11/23/2019</b>		<b>Date Results Received: 12/6/2019</b>	
<b>Number of Faucets Tested: 30</b>			
<b>Lead Results</b>		<b>Copper Results</b>	
Results 15 ppb and above:	6	Results 1.3 ppm and above:	0
Results 10 ppb to below 15 ppb:	0	Detectable results below 1.3 ppm:	29
Detectable results below 10 ppb:	11	Results below detection level:	1
Results below detection level:	13		
<b>Number of Faucets Requiring Remedial Action: 6</b>			
<b>Location of Faucet</b>		<b>Action Taken</b>	<b>Date:</b>
Sample ID: MTA-001-008-DS-P, MTA-001-017-DS-P, MTA-001-023-DS-P, MTA-001-024-DS-P, MTA-001-026-DS-P, MTA-001-030-DS-P		<input checked="" type="checkbox"/> Temporarily taken out of service:	12/12/2019
		<input checked="" type="checkbox"/> Permanently taken out of service:	1/3/2020
Location Description: MTA-001-008-DS-P: drinking station in room 5 MTA-001-017-DS-P: drinking station in room 12 MTA-001-023-DS-P: drinking station in room 23 MTA-001-024-DS-P: drinking station in room 21 MTA-001-026-DS-P: drinking station in room 24 MTA-001-030-DS-P: drinking station in room 16		<input checked="" type="checkbox"/> Flush tested:	12/14/2019
		Flush test result: No exceedances	
		<input type="checkbox"/> Replaced:	
		<input type="checkbox"/> Retest:	
		Retest result:	
		Other: _____	
		<input type="checkbox"/> Placed back in service on:	
<b>Daily School-Wide Flushing:</b>			
<input type="checkbox"/> Continue with protocol <input checked="" type="checkbox"/> Discontinue flushing protocol (date): 12/27/2019 <input type="checkbox"/> Other (Describe: )			
This is a summary report prepared by Hart & Hickman, PC (H&H). H&H suggests that the full report be referred to with regard to findings, recommendations, and technical limitations for this sampling event.			