

| | | | |
|--|---|---|--------------|
| School Name: Pruette Scale School | | Report Date(s): 3/25/2020 | |
| Date Test Conducted: 3/14/2020 | | Date Results Received: 3/24/2020 | |
| Number of Faucets Tested: 8 | | | |
| Lead Results | | Copper Results | |
| Results 15 ppb and above: | 0 | Results 1.3 ppm and above: | 0 |
| Results 10 ppb to below 15 ppb: | 0 | Detectable results below 1.3 ppm: | 7 |
| Detectable results below 10 ppb: | 3 | Results below detection level: | 1 |
| Results below detection level: | 5 | | |
| Number of Faucets Requiring Remedial Action: 0 | | | |
| Location of Faucet | | Action Taken | Date: |
| Sample ID: | | <input type="checkbox"/> Temporarily taken out of service: <input type="checkbox"/> Permanently taken out of service: <input type="checkbox"/> Flush tested: Flush test result: <input type="checkbox"/> Replaced: <input type="checkbox"/> Retest: Retest result: Other: _____ <input type="checkbox"/> Placed back in service on: | |
| Location Description: | | | |
| Daily School-Wide Flushing: | | | |
| <input type="checkbox"/> Continue with protocol <input checked="" type="checkbox"/> Discontinue flushing protocol (date): 3/25/20 <input type="checkbox"/> Other (Describe: _____) | | | |
| This is a summary report prepared by Hart & Hickman, PC (H&H). H&H suggests that the full report be referred to with regard to findings, recommendations, and technical limitations for this sampling event. | | | |