

<b>School Name: Sedalia Elementary</b>		<b>Report Date (s): 6/17/19; 8/19/9</b>	
<b>Date Test Conducted: 5/8/19</b>		<b>Date Results Received: 5/17/19</b>	
<b>Number of Faucets Tested: 33</b> (all GCS identified faucets used for drinking/food preparation)			
<b>Lead Results</b>		<b>Copper Results</b>	
<b>Results 15 ppb and above: 1</b>		<b>Results 1.3 ppm and above: 0</b>	
<b>Results 10 ppb to below 15 ppb: 0</b>		<b>Detectable results below 1.3 ppm: 33</b>	
<b>Detectable results below 10 ppb: 1</b>		<b>Results below detection level: 0</b>	
<b>Results below detection level: 31</b>			
<b>Number of Faucets Requiring Remedial Action: 1</b>			
<b>Location of Faucet</b>		<b>Action Taken</b>	
Sample ID: 017 (19.7 ug/L)  Location description: Room 19 Drinking Station		x Temporarily Taken Out of Service: 5/20/19 x Permanently Taken Out of Service: 6/6/19 x Flush Tested: 5/21/19 Flush Test Result 6/1/19: ND (Lead) __ Replaced: mm/dd/yyyy __ Retest: mm/dd/yyyy Retest Result: ##### __ Other: _____mm/dd/yyyy __ Placed Back in Service on: mm/dd/yyyy	
Daily School-Wide Flushing: __ Continue with protocol __ Discontinue flushing protocol: mm/dd/yyyy <u>X</u> Other (Describe: <u>Perform Periodic Flushing</u> )			
This is a summary report prepared by ECS. ECS suggests that the full report be referred to with regards to findings, recommendations, and technical limitations for this sampling event.			