

School Name: Stokesdale Elementary		Report Date (s): 5/22/19; 8/19/19	
Date Test Conducted: 5/7/19		Date Results Received: 5/21/19	
Number of Faucets Tested: 30 (all GCS identified faucets used for drinking/food preparation)			
Lead Results		Copper Results	
Results 15 ppb and above: 2		Results 1.3 ppm and above: 0	
Results 10 ppb to below 15 ppb: 1		Detectable results below 1.3 ppm: 29	
Detectable results below 10 ppb: 2		Results below detection level: 1	
Results below detection level: 25			
Number of Faucets Requiring Remedial Action: 3			
Location of Faucet		Action Taken	
Sample ID: 012 (Lead 9.9 ppb) Location description: Room B06 Drinking Station		x Temporarily Taken Out of Service: 5/22/19 x Permanently Taken Out of Service: 6/7/19 x Flush Tested: 5/23/19 Flush Test Result 6/1/19: ND (Lead) ___ Replaced: mm/dd/yyyy ___ Retest: mm/dd/yyyy Retest Result: ##### ___ Other: _____mm/dd/yyyy ___ Placed Back in Service on: mm/dd/yyyy	
Sample ID: 021R (Lead 29.2 ppb) Location description: Right-hand Drinking Station between Rooms C103 and C101		x Temporarily Taken Out of Service: 5/22/19 x Permanently Taken Out of Service: 6/7/19 x Flush Tested: 5/23/19 Flush Test Result 6/1/19: ND (Lead) ___ Replaced: mm/dd/yyyy ___ Retest: mm/dd/yyyy Retest Result: ##### ___ Other: _____mm/dd/yyyy ___ Placed Back in Service on: mm/dd/yyyy	
Sample ID: 022L (Lead 242 ppb) Location description: Left-hand Drinking Station between Rooms C103 and C101		x Temporarily Taken Out of Service: 5/22/19 x Permanently Taken Out of Service: 6/7/19 x Flush Tested: 5/23/19 Flush Test Result 6/1/19: ND (Lead) ___ Replaced: mm/dd/yyyy ___ Retest: mm/dd/yyyy Retest Result: ##### ___ Other: _____mm/dd/yyyy ___ Placed Back in Service on: mm/dd/yyyy	
Daily School-Wide Flushing: ___ Continue with protocol ___ Discontinue flushing protocol: mm/dd/yyyy <u>X</u> Other (Describe: <u>Perform Periodic Flushing</u>)			
This is a summary report prepared by ECS. ECS suggests that the full report be referred to with regards to findings, recommendations, and technical limitations for this sampling event.			