

Table 1
Summary of First-Draw Drinking Water Analytical Results
Guilford County Schools
Vandalia Elementary
Greensboro, North Carolina
H&H Job No. GCS-001

Sample ID	Guilford County Sample Location Code	Sampling Date	Analytical Method	Lead	Copper
				ppb ⁽¹⁾	ppm ⁽²⁾
VAN-001-001-KF-P	001	11/2/2019	200.8	<2.0	0.010
VAN-001-002-KF-P	002	11/2/2019		<2.0	0.0096
VAN-001-003-KF-P	003	11/2/2019		<2.0	0.023
VAN-001-004-KF-P	004	11/2/2019		<2.0	0.011
VAN-001-006-IM-P	006	11/2/2019		<2.0	<0.0020
VAN-001-007-WC-P	007	11/2/2019		<2.0	0.038
VAN-001-008-WC-P	008	11/2/2019		<2.0	0.19
VAN-001-009-WC-P	009	11/2/2019		<2.0	0.018
VAN-001-010-WC-P	010	11/2/2019		<2.0	0.023
VAN-001-011-WC-P	011	11/2/2019		<2.0	0.068
VAN-001-012-KF-P	012	11/2/2019		<2.0	0.035
VAN-001-013-WC-P	013	11/2/2019		<2.0	0.032
VAN-001-014-WC-P	014	11/2/2019		<2.0	0.019
VAN-001-015-WC-P	015	11/2/2019		<2.0	0.015
VAN-001-016-WC-P	016	11/2/2019		<2.0	0.024
VAN-001-017-WC-P	017	11/2/2019		9.0	6.4
VAN-001-018-WC-P	018	11/2/2019		<2.0	0.019
District Threshold ⁽³⁾				10	1.3

Notes

- 1.) Lead results reported in parts per billion (ppb).
 - 2.) Copper results reported in parts per million (ppm).
 - 3.) Remediation threshold established by Guilford County Schools.
- Concentrations in **bold** exceed the remediation threshold established by Guilford County Schools.