

<b>School Name: Vandalia Elementary</b>		<b>Report Date(s): 1/24/2020</b>	
<b>Date Test Conducted: 11/2/2019</b>		<b>Date Results Received: 11/13/2019</b>	
<b>Number of Faucets Tested: 17</b>			
<b>Lead Results</b>		<b>Copper Results</b>	
Results 15 ppb and above:	0	Results 1.3 ppm and above:	1
Results 10 ppb to below 15 ppb:	0	Detectable results below 1.3 ppm:	15
Detectable results below 10 ppb:	1	Results below detection level:	1
Results below detection level:	16		
<b>Number of Faucets Requiring Remedial Action: 1</b>			
<b>Location of Faucet</b>		<b>Action Taken</b>	<b>Date:</b>
Sample ID: VAN-001-017-WC-P		<input checked="" type="checkbox"/> Temporarily taken out of service:	11/14/2019
Location Description: water cooler in mobile unit #2		<input type="checkbox"/> Permanently taken out of service:	
		<input checked="" type="checkbox"/> Flush tested:	11/22/2019
		Flush test result: no exceedances	
		<input checked="" type="checkbox"/> Replaced:	12/17/2019
		<input checked="" type="checkbox"/> Retest:	1/11/2020
		Retest result: no exceedances	
		Other: _____	
		<input checked="" type="checkbox"/> Placed back in service on:	1/24/2020
<b>Daily School-Wide Flushing:</b>			
<input type="checkbox"/> Continue with protocol <input checked="" type="checkbox"/> Discontinue flushing protocol (date): 1/24/20 <input type="checkbox"/> Other (Describe: )			
This is a summary report prepared by Hart & Hickman, PC (H&H). H&H suggests that the full report be referred to with regard to findings, recommendations, and technical limitations for this sampling event.			