

Phase 2 Water Quality Initiative - Interim Report Addendum

As indicated in the Phase 2 Water Quality Initiative Interim Report, the following table indicates where the initial first-draw water sample tested higher than the GCS-determined action level for lead of 10 parts per billion (ppb). The EPA action level for lead in water for residential use is 15 ppb. The faucets were removed from service prior to school the next day.

<u>School</u>	<u>Sample ID</u>	<u>Sample Date</u>	<u>Location</u>	<u>Initial 1st Draw Concentration</u>
Allen Jay Elementary	011-AJE	11/21/18	Main Building, Room 11 Drinking Station	66 ppb
Allen Jay Elementary	S01-AJE	11/21/18	Kitchen Area, Steamer/Comb	11 ppb
Frazier Elementary	FES-247	11/21/18	Clinic Sink	83 ppb
Foust Elementary	FES-WC1	12/19/18	Hallway: Left Water Cooler Near Rm 65	64 ppb
Penn Griffin Middle	PGM-003	12/20/18	Cafeteria: Basin Pan	10 ppb